



Montage - Assembly - Montage - Montaje - Montaggio -
Montering - Asennus - монтаж - Montaž



Demontage - Disassembly - Démontage - Demontage Demontaggio -
Desmontaje - Demontering - Purkaminen - демонтаж - Demontaž




For 24 V: Valve Drive has to be powered by a 24 V safety transformer according to EN 61558-2-6 (Europe) with a maximum power output of 100 VA or class II - UL approved (North America).




NC - NORMALLY CLOSED

OPTIONAL


"First Open" Funktion - "First Open" function - Fonction "First Open" - Función de contacto abierto - "First Open" functie - Funzione "First Open" - "First Open" funksjon - "Förstagången" funktion - "First Open" toiminta - функция „first open” - Funkcja „first open”



Anpassungskontrolle - Adaption check - Contrôle de l'ajustement - Aanpassingscontrole - Control de adaptación - Controllo del combadamento - Tilpasningskontroll - Justeringskontroll - Sopivuuden tarkistus - контроль приспособления - Kontrola dopasowania



Funktionsweise - Function mode - Mode de fonctionnement - Funcionamiento - Werkwijze - Modo di funzione - Funktionsmåde - Funksjonsmodus - Funktionsätt - Toimintaperiaate - принцип действия - Zasada działania



A 1004 / A 2004 / A 4004