

Drain Tee Cap & Hose Connection

Z-VENT[®] Drain Tee Caps are equipped with a ½ inch diameter drain fitting to allow the evacuation of condensate from the vent system.

Z-Flex[®] recommends the installation of the tube kit 2SVEDTK__ to facilitate the evacuation of the condensate to a suitable drain or neutralizing system.

The Tube Kit Contains:

- 1 - ½ inch wire (hose) clamp
- 2 - Cable ties
- 1 - ¾ inch ID / ⅝ inch OD Silicone Tube (various lengths)



1. Open wire clamp with pliers and slide over the tubing.
2. Form a 3 inch loop in the tubing and affix the cable tie to complete the p-trap.
3. Fill the p-trap with water.
4. Affix the tubing onto the drain fitting.
5. Open the wire clamp and slide the clamp back to the end of the tube over the drain fitting and release.
6. This tube can be extended by adding suitable size hose and nipple connection.

Detailed installation instructions can be viewed at www.z-flex.com

The information provided within is for informational purposes only. We have made every effort to ensure the accuracy of the provided information and assume no responsibility for any loss or damage due to errors or omissions or to the use or misuse of any information supplied. It is impossible to test all products under all conditions to which they might be subjected in the field. It is therefore the buyer and/or end users' responsibility to test all products under the conditions that duplicate the service conditions prior to installation. All improvements, all specifications are subject to change without prior notice. It is the buyer and/or end users' responsibility to review our complete Terms and Conditions of Sale located on our web sites at: www.novaflex.com | www.z-flex.com | www.flexmaster.com.

OINSTSUPTCD - SUPPLEMENT INSTRUCTION DRAIN TEE rev 06.2019

Z-VENT[™] is manufactured by Z-Flex[®] US, a Novaflex Group Company

Canada: 452 Attwell Drive, Etobicoke, ON M9W 5C3 tel: 416.679.0045 • fax: 416.679.0051
USA: 20 Commerce Park North, Bedford, New Hampshire tel: 603.669.5136 800.654.5600 • fax: 603.669.0309